



Lead Sample Collection Information

School District Name: Hockinson School District

School Name: Hockinson Heights Elementary School

School Code: 5311

Address: 20000 NE 164th Street Brush Prairie, WA 98608

Number of Samples Collected: 109

Date Collected: 2/1/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	501	First Draw	Bubbler	Room 605	2	2/9/2018	
Sample 2	502	First Draw	Tap	Room 605	1	2/9/2018	
Sample 3	503	First Draw	Bubbler	Room 601	<1	2/9/2018	
Sample 4	504	First Draw	Tap	Room 601	<1	2/9/2018	
Sample 5	505	First Draw	Bubbler	Room 602	<1	2/9/2018	
Sample 6	506	First Draw	Tap	Room 602	1	2/9/2018	
Sample 7	507	First Draw	Bubbler	Room 603	<1	2/9/2018	
Sample 8	508	First Draw	Tap	Room 603	1	2/9/2018	
Sample 9	509	First Draw	Bubbler	Room 604	<1	2/9/2018	
Sample 10	510	First Draw	Tap	Room 604	<1	2/9/2018	
Sample 11	511	First Draw	Tap	Blue Kitchen	TB	2/9/2018	
Sample 12	512	First Draw	Bubbler	Blue Gym	1	2/9/2018	
Sample 13	513	First Draw	Bubbler	Room 901	1	2/9/2018	
Sample 14	514	First Draw	Tap	Room 901	<1	2/9/2018	
Sample 15	515	First Draw	Bubbler	Room 902	<1	2/9/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 16	516	First Draw	Tap	Room 902	1	2/9/2018	
Sample 17	517	First Draw	Bubbler	Room 903	<1	2/9/2018	
Sample 18	518	First Draw	Tap	Room 903	2	2/9/2018	
Sample 19	519	First Draw	Bubbler	Room 904	<1	2/9/2018	
Sample 20	520	First Draw	Tap	Room 904	2	2/9/2018	
Sample 21	521	First Draw	Bubbler	Room 905	<1	2/9/2018	
Sample 22	522	First Draw	Tap	Room 905	2	2/9/2018	
Sample 23	523	First Draw	Bubbler	Room 906	<1	2/9/2018	
Sample 24	524	First Draw	Tap	Room 906	9	2/9/2018	
Sample 25	525	First Draw	Bubbler	Room 808	3	2/9/2018	
Sample 26	526	First Draw	Tap	Room 808	2	2/9/2018	
Sample 27	527	First Draw	Bubbler	Room 801	1	2/9/2018	
Sample 28	528	First Draw	Tap	Room 801	1	2/9/2018	
Sample 29	529	First Draw	Bubbler	Room 802	3	2/9/2018	
Sample 30	530	First Draw	Tap	Room 802	3	2/9/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 31	531	First Draw	Bubbler	Room 803	7	2/9/2018	
Sample 32	532	First Draw	Tap	Room 803	4	2/9/2018	
Sample 33	533	First Draw	Bubbler	Room 804	4	2/9/2018	
Sample 34	534	First Draw	Tap	Room 804	2	2/9/2018	
Sample 35	535	First Draw	Bubbler	Room 700	1	2/9/2018	
Sample 36	536	First Draw	Tap	Room 700	1	2/9/2018	
Sample 37	537	First Draw	Bubbler	Room 701	<1	2/9/2018	
Sample 38	538	First Draw	Tap	Room 701	<1	2/9/2018	
Sample 39	539	First Draw	Bubbler	Room 702	<1	2/9/2018	
Sample 40	540	First Draw	Tap	Room 702	1	2/9/2018	
Sample 41	541	First Draw	Bubbler	Room 703	<1	2/9/2018	
Sample 42	542	First Draw	Tap	Room 703	1	2/9/2018	
Sample 43	543	First Draw	Bubbler	Room 704	1	2/9/2018	
Sample 44	544	First Draw	Tap	Room 704	<1	2/9/2018	
Sample 45	545	First Draw	Bubbler	Room 117	3	2/9/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 46	546	First Draw	Tap	Room 117	2	2/9/2018	
Sample 47	547	First Draw	Bubbler	Room 913	2	2/9/2018	
Sample 48	548	First Draw	Tap	Room 913	3	2/9/2018	
Sample 49	549	First Draw	Bubbler	Room 914	2	2/9/2018	
Sample 50	550	First Draw	Tap	Room 914	3	2/9/2018	
Sample 51	551	First Draw	Bubbler	Room 911	1	2/9/2018	
Sample 52	552	First Draw	Tap	Room 911	1	2/9/2018	
Sample 53	553	First Draw	Bubbler	Room 912	1	2/9/2018	
Sample 54	554	First Draw	Tap	Room 912	2	2/9/2018	
Sample 55	555	First Draw	Bubbler	Room 907	<1	2/9/2018	
Sample 56	556	First Draw	Tap	Room 907	1	2/9/2018	
Sample 57	557	First Draw	Bubbler	Room 908	<1	2/9/2018	
Sample 58	558	First Draw	Tap	Room 908	2	2/9/2018	
Sample 59	559	First Draw	Bubbler	Room 300	3	2/9/2018	
Sample 60	560	First Draw	Tap	Room 300	2	2/9/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 61	561	First Draw	Bubbler	Room 301	3	2/9/2018	
Sample 62	562	First Draw	Tap	Room 301	1	2/9/2018	
Sample 63	563	First Draw	Bubbler	Room 304	3	2/9/2018	
Sample 64	564	First Draw	Tap	Room 304	3	2/9/2018	
Sample 65	565	First Draw	Bubbler	Room 305	1	2/9/2018	
Sample 66	566	First Draw	Tap	Room 305	2	2/9/2018	
Sample 67	567	First Draw	Bubbler	Room 308	<1	2/9/2018	
Sample 68	568	First Draw	Tap	Room 308	2	2/9/2018	
Sample 69	569	First Draw	Bubbler	Room 309	<1	2/9/2018	
Sample 70	570	First Draw	Tap	Room 309	1	2/9/2018	
Sample 71	571	First Draw	Bubbler	Room 310	<1	2/9/2018	
Sample 72	572	First Draw	Tap	Room 310	1	2/9/2018	
Sample 73	573	First Draw	Bubbler	Room 311	2	2/9/2018	
Sample 74	574	First Draw	Tap	Room 311	2	2/9/2018	
Sample 75	575	First Draw	Bubbler	Room 219	<1	2/9/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 76	576	First Draw	Tap	Room 219	<1	2/9/2018	
Sample 77	577	First Draw	Bubbler	Room 218	<1	2/9/2018	very low function
Sample 78	578	First Draw	Tap	Room 218	1	2/9/2018	
Sample 79	579	First Draw	Bubbler	Room 217	1	2/9/2018	
Sample 80	580	First Draw	Tap	Room 217	2	2/9/2018	
Sample 81	581	First Draw	Bubbler	Room 216	1	2/9/2018	
Sample 82	582	First Draw	Tap	Room 216	2	2/9/2018	
Sample 83	583	First Draw	Bubbler	Room 200	1	2/9/2018	
Sample 84	584	Other	Tap	Room 200	<1	2/9/2018	was used prior to sampling
Sample 85	585	First Draw	Bubbler	Room 201	1	2/9/2018	
Sample 86	586	First Draw	Tap	Room 201	<1	2/9/2018	
Sample 87	587	First Draw	Tap	Room 210	1	2/9/2018	Tap OK, no function in bubbler
Sample 88	588	First Draw	Bubbler	Room 211	3	2/9/2018	
Sample 89	589	First Draw	Tap	Room 211	1	2/9/2018	
Sample 90	590	First Draw	Bubbler	Room 213	<1	2/9/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 91	591	First Draw	Tap	Room 213	1	2/9/2018	
Sample 92	592	First Draw	Bubbler	Room 214	<1	2/9/2018	
Sample 93	593	First Draw	Tap	Room 214	1	2/9/2018	
Sample 94	594	First Draw	Bubbler	Room 215	1	2/9/2018	
Sample 95	595	First Draw	Tap	Room 215	TB	2/9/2018	
Sample 96	596	Other	Bubbler	Room 212	<1	2/9/2018	used prior to sampling
Sample 97	597	First Draw	Tap	Room 212	1	2/9/2018	
Sample 98	598	First Draw	Tap	Room 111	2	2/9/2018	Big Sink in main room
Sample 99	599	First Draw	Tap	Room 111	<1	2/9/2018	Little sink in back room
Sample 100	600	First Draw	Tap	Library	1	2/9/2018	
Sample 101	601	First Draw	Bubbler	Yellow Gym	<1	2/9/2018	
Sample 102	602	First Draw	Bubbler	Yellow Lunch Room	<1	2/9/2018	In front of Yellow Gym
Sample 103	603	First Draw	Bubbler	Room 114	10	2/9/2018	
Sample 104	604	First Draw	Tap	Room 114	<1	2/9/2018	
Sample 105	605	First Draw	Tap	West Office	1	2/9/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 106	606	Other	Bubbler	Room 916	<1	2/9/2018	used prior to sampling
Sample 107	607	First Draw	Tap	Room 916	<1	2/9/2018	
Sample 108	608	Other	Bubbler	Room 915	<1	2/9/2018	used prior to sampling
Sample 109	609	First Draw	Tap	Room 915	1	2/9/2018	